

## Positioning Devices - Component

**COMPANY**

**ADVANCED CABLE TIES INC**  
 245 SUFFOLK LN  
 GARDNER, MA 01440-1761 United States


E168851

**Cable Ties Investigated to ANSI/UL 62275**

Cat. No.	Type	Bundle Dia.		Loop Tensile Str. N	Operating Temp.		Min. Install. Temp. °C	Resistant to UV Light	IEC 62275 Type
		mm			°C				
		Min	Max		Min	Max			
<b>Cable Tie (Nonmetallic)</b>									
AP(R,L)-07-50-CW-0	11	3.18	47.6	222	-40	65	-40	Y	-
AP(R,L)-11-50-CW-0	11	3.18	77.7	222	-40	65	-40	Y	-
AP(R,L)-14-120-CW-0	11	4.75	103.1	534	-40	65	-40	Y	-
AP(R,L)-14-50-CW-0	11	3.18	101.6	222	-40	65	-40	Y	-

**Fixing Devices Investigated to ANSI/UL 62275**

Cat. No.	Type	Mechanical		Hole Dia. mm	Panel Thick. mm	Operating Temp.		Resistant to UV Light	IEC 62275 Type
		Str. N				°C			
		Min	Max			Min	Max		
<b>Fixing Device</b>									
AP(R,L)-MP-1000-#	11	50	-	-	-	-20	70	-	-
AP(R,L)-MP-750-#	11	40	-	-	-	-20	70	-	-
AP(R,L)-MPA-1000-#	11	50	-	-	-	-20	70	-	-
AP(R,L)-MPA-750-#	11	40	-	-	-	-20	70	-	-
AP(R,L)-MPNT-1000-#	11	50	-	-	-	-20	70	-	-
AP(R,L)-MPNT-750-#	11	40	-	-	-	-20	70	-	-

Marking: Company name, catalog or model number and the Recognized Component Mark, . If published with the product, the product's maximum and minimum operating temperature, minimum installation temperature if below 0°C, minimum and maximum bundle

diameter, loop tensile strength, type designation and/or declared mechanical strength on the product or on the smallest unit container in which the product is packaged.

Last Updated on 2022-10-27

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."